



CORRIGENDUM

With reference to tender no: AIIMS/Pat/Tender/Anatomy/LabFur/136 dated 17/01/2017, regarding tender for Setting up of Laboratory for Department of Anatomy at AIIMS Patna, a pre-bid meeting was held on 24/01/2017 in committee hall, medical college building, AIIMS Patna.

The issue raised by the firms were discussed and the committee recommended for the following corrigendum to be issued:-

5. Point no. 1.8.5- Slidable regent rack/shelves construction of page no 23 of the tender document
 - A) It should be read as "construction of shelves bracket shall be of Aluminium Pressure Die Cast/GI Steel sheets"
 - B) In the tender document at page no.27-Approved make of Materials for 4 Fume Hood System-it should be deleted as there is no fume hood in tender drawings.
6. *The last date of submission of tender documents is extended up to 16-03-2017, 14.00 hrs and it will open on 16/03/2017 at 15:30 hrs.*

sd/=

**Faculty In-charge
Procurement Cell
AIIMS, Patna**